

For Immediate Release

Investment Corporation

Canadian Solar Infrastructure Fund, Inc.
 Representative: Hiroshi Yanagisawa
 Executive Officer
 (Securities Code: 9284)

Asset Manager

Canadian Solar Asset Management K.K.
 Representative: Hiroshi Yanagisawa
 CEO & Representative Director
 Inquiries: Keiichi Yoshida
 CFO & Director
 TEL: +81-3-6279-0311

The Solar Power Generation and CO2 Reduction Data

Canadian Solar Infrastructure Fund, Inc. (hereinafter referred to as “The Fund”) hereby announce its Solar Power Generation and CO2 Reduction data for June 2024.

1. Monthly Solar Power Generation and CO2 Reduction Data

FY of June, 2024						
	Total PV Facilities	Solar Module Output (MW)	Forecast Power Generation (kWh) (A) (*1)	Actual Power Generation (kWh) (B) (*2)	Difference (kWh) (B) - (A)	CO2 Reduction (kg-CO2) (*3)
January	31	226.43	15,187,404	15,995,708	808,304	7,091,580
February	31	226.43	16,748,699	15,301,682	-1,447,017	6,631,506
March	31	226.43	22,188,314	22,620,729	432,414	9,824,480
April	31	226.43	25,656,566	19,826,856	-5,829,710	8,610,201
May	31	226.43	25,710,442	24,597,092	-1,113,350	10,671,667
June	31	226.43	21,830,275	23,051,907	1,221,631	9,987,425
Total	-	-	127,321,701	121,393,974	-5,927,727	52,816,859

(*1) Forecast Power Generation is based on the Forecast Power Generation (P50) provided in the independent technical report.

(*2) Actual Power Generation is based on SCADA (Supervisory Control and Data Acquisition) system data generation.

(*3) CO2 reduction is calculated as based on adjusted emission coefficient by electric power companies. For more details, please refer to the link (<https://www.env.go.jp/press/104919.html>).

2. Solar Power Generation During the Month of June 2024

The Fund portfolio generated actual power generation of 23,051,907kWh during the month of June 2024, equivalent to 105.60% of the forecasted power generation, primarily due to a strong solar radiation during the month although some areas had many rains in the latter part of the month. At individual PV level, i) the CS Enashi PV fell far short of the forecast as it was still impacted by the cable theft that occurred in January, and ii) the CS Ogawara-machi PV fell far short of the forecast due to a partial failure of PCS.

Month of June 2024				
PV Facility	Solar Module Output (MW)	Forecast Power Generation (kWh) (A)	Actual Power Generation (kWh) (B)	Actual vs Forecast (%) (B/A)
CS Shibushi-shi	1.22	101,409	92,504	91.22%
CS Isa-shi	0.93	77,772	82,780	106.44%
CS Kasama-shi	2.13	201,264	233,534	116.03%
CS Isa-shi Dai-ni	2.01	178,616	177,600	99.43%
CS Yusui-cho	1.75	170,462	147,620	86.60%
CS Isa-shi Dai-sand	2.23	188,639	209,389	111.00%
CS Kasama-shi Dai-ni	2.10	200,750	233,938	116.53%
CS Hiji-machi	2.57	246,104	264,439	107.45%
CS Ashikita-machi	2.35	204,328	210,381	102.96%
CS Minamishimabara-shi (E)(W)	3.93	360,789	358,790	99.45%
CS Minano-machi	2.45	225,953	239,013	105.78%
CS Kannami-cho	1.34	131,823	136,414	103.48%
CS Mashiki-machi	47.69	4,362,926	4,437,000	101.70%
CS Koriyama-shi	0.64	60,576	81,518	134.57%
CS Tsuyama-shi	1.93	188,887	197,470	104.54%
CS Ena-shi	2.12	203,289	158,620	78.03%
CS Daisen-cho (A)(B)	27.30	2,491,400	3,102,000	124.51%
CS Takayama-shi	0.96	97,421	113,481	116.48%
CS Misato-machi	1.08	100,148	113,351	113.18%
CS Marumori-machi	2.19	204,673	262,195	128.10%
CS Izu-shi	10.78	1,106,000	1,196,590	108.19%
CS Ishikari Shinshinotsu-mura	2.38	288,738	331,061	114.66%
CS Osaki-shi Kejonuma	0.95	93,261	109,013	116.89%
CS Hiji-machi Dai-ni	53.40	5,023,639	5,203,800	103.59%
CS Ogawara-machi	7.51	786,522	605,210	76.95%
CS Fukuyama-shi	3.32	375,985	355,550	94.56%
CS Shichikashuku-machi	9.21	1,120,028	1,252,940	111.87%
CS Kama-shi	2.24	192,685	191,049	99.15%
CS Miyako-machi Saigawa	13.01	1,199,534	1,200,588	100.09%
CS Kasama-shi Dai-san	13.57	1,512,960	1,625,550	107.44%



CS Yamaguchi-shi	1.11	133,693	128,520	96.13%
Portfolio Total	226.43	21,830,275	23,051,907	105.60%

End

URL: <https://www.canadiansolarinfra.com/en/>