

For Immediate Release

Investment Corporation

Canadian Solar Infrastructure Fund, Inc.

 Representative: Hiroshi Yanagisawa
 Executive Officer
 (Securities Code: 9284)

Asset Manager

Canadian Solar Asset Management K.K.

 Representative: Hiroshi Yanagisawa
 CEO & Representative Director

 Inquiries: Keiichi Yoshida
 CFO & Director
 TEL: +81-3-6279-0311

The Solar Power Generation and CO2 Reduction Data

Canadian Solar Infrastructure Fund, Inc. (hereinafter referred to as “The Fund”) hereby announce its Solar Power Generation and CO2 Reduction data for July 2024.

1. Monthly Solar Power Generation and CO2 Reduction Data

FY of December 2024						
	Total PV Facilities	Solar Module Output (MW)	Forecast Power Generation (kWh) (A) (*1)	Actual Power Generation (kWh) (B) (*2)	Difference (kWh) (B) - (A)	CO2 Reduction (kg-CO2) (*3)
July	31	226.43	24,411,967	25,868,400	1,456,433	11,177,044
August						
September						
October						
November						
December						
Total	-	-	24,411,967	25,868,400	1,456,433	11,177,044

(*1) Forecast Power Generation is based on the Forecast Power Generation (P50) provided in the independent technical report.

(*2) Actual Power Generation is based on SCADA (Supervisory Control and Data Acquisition) system data generation.

(*3) CO2 reduction is calculated as based on adjusted emission coefficient by electric power companies. For more details, please refer to the link (<https://www.env.go.jp/press/104919.html>).

2. Solar Power Generation During the Month of July 2024

The Fund portfolio generated actual power generation of 25,868,400kWh during the month of July 2024, equivalent to 105.97% of the forecasted power generation, due to a better than expected irradiance primarily in Kyushu area and limited curtailment during the month. At individual PV level, i) the CS Ena-shi PV fell far short of the forecast as it was still impacted by the cable theft that occurred in January, and ii) the CS Ogawara-machi PV fell far short of the forecast due to a partial failure of PCS.

Month of July 2024				
PV Facility	Solar Module Output (MW)	Forecast Power Generation (kWh) (A)	Actual Power Generation (kWh) (B)	Actual vs Forecast (%) (B/A)
CS Shibushi-shi	1.22	128,376	154,672	120.48%
CS Isa-shi	0.93	97,108	111,750	115.08%
CS Kasama-shi	2.13	200,167	235,891	117.85%
CS Isa-shi Dai-ni	2.01	222,921	227,300	101.96%
CS Yusui-cho	1.75	184,855	208,720	112.91%
CS Isa-shi Dai-sand	2.23	244,331	288,154	117.94%
CS Kasama-shi Dai-ni	2.10	199,371	236,122	118.43%
CS Hiji-machi	2.57	301,125	336,866	111.87%
CS Ashikita-machi	2.35	274,771	278,221	101.26%
CS Minamishimabara-shi (E)(W)	3.93	462,378	473,941	102.50%
CS Minano-machi	2.45	237,768	210,329	88.46%
CS Kannami-cho	1.34	151,395	137,135	90.58%
CS Mashiki-machi	47.69	5,249,653	5,331,100	101.55%
CS Koriyama-shi	0.64	61,150	67,096	109.72%
CS Tsuyama-shi	1.93	185,146	181,730	98.16%
CS Ena-shi	2.12	219,349	150,910	68.80%
CS Daisen-cho (A)(B)	27.30	2,684,375	2,999,400	111.74%
CS Takayama-shi	0.96	103,090	94,326	91.50%
CS Misato-machi	1.08	103,790	107,748	103.81%
CS Marumori-machi	2.19	188,691	220,615	116.92%
CS Izu-shi	10.78	1,280,190	1,383,240	108.05%
CS Ishikari Shinshinotsu-mura	2.38	269,077	316,012	117.44%
CS Osaki-shi Kejonuma	0.95	88,384	90,692	102.61%
CS Hiji-machi Dai-ni	53.40	5,741,688	6,649,500	115.81%
CS Ogawara-machi	7.51	747,558	358,270	47.93%
CS Fukuyama-shi	3.32	428,310	439,970	102.72%
CS Shichikashuku-machi	9.21	1,040,649	1,023,270	98.33%
CS Kama-shi	2.24	228,817	244,214	106.73%
CS Miyako-machi Saigawa	13.01	1,484,308	1,525,836	102.80%

CS Kasama-shi Dai-san	13.57	1,459,743	1,647,100	112.83%
CS Yamaguchi-shi	1.11	143,434	138,270	96.40%
Portfolio Total	226.43	24,411,967	25,868,400	105.97%

End

URL: <https://www.canadiansolarinfra.com/en/>